

MINNESOTA VALLEY TESTING LABORATORIES, INC.

MVTL

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 E. Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Highway ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvfl.com

MEMBER
ACIL

Report Date: 5 Jul 2018

BRIAN CRABTREE
SOUTHEASTERN MN WATER ANALYSIS LAB.
2100 CAMPUS DR SE
ROCHESTER MN 55904


Work Order #: 12-10473
Account #: 018232
Purchase Order #: CREDIT CARD

Date Received: 21 Jun 2018
Date Sampled: 19 Jun 2018
Time Sampled: 7:06
Temperature at Receipt: AMBIENT

PROJECT NAME: CITY OF BYRON

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
18-A30978	ZUMBRO EDUCATION DISTRICT 221 2ND AVE SW BYRON, MN 55920	< 0.5 ug/L	15.0	3 Jul 18	RMV
18-A30979	ZUMBRO EDUCATION DISTRICT 221 2ND AVE SW BYRON, MN 55920	3.22 ug/L	15.0	3 Jul 18	RMV
18-A30980	ZUMBRO EDUCATION DISTRICT 221 2ND AVE SW BYRON, MN 55920	0.83 ug/L	15.0	3 Jul 18	RMV
18-A30981	ZUMBRO EDUCATION DISTRICT 221 2ND AVE SW BYRON, MN 55920	< 0.5 ug/L	15.0	3 Jul 18	RMV
18-A30982	ZUMBRO EDUCATION DISTRICT 221 2ND AVE SW BYRON, MN 55920	1.72 ug/L	15.0	3 Jul 18	RMV
18-A30983	ZUMBRO EDUCATION DISTRICT 221 2ND AVE SW BYRON, MN 55920	0.70 ug/L	15.0	3 Jul 18	RMV

Approved by:



Dan O'Connell

David Smahel

Chemistry Laboratory Managers New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards. The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix

= Due to concentration of other analytes

! = Due to sample quantity

+ = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER